

CERTIFICATE OF COMPLIANCE

Certificate Number 20190509-R38702
Report Reference R38702-20190329
Issue Date 2019-MAY-09

Issued to: Kent Smoke and Fire Curtains
No 10, 7th street, AL-QUSAIS INDUSTRIAL AREA 2
Dubai UNITED ARAB EMIRATE

This certificate confirms that representative samples of FIRE-PROTECTIVE CURTAINS
See addendum page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 10D - Standard for Fire Tests of Fire Protective Curtain Assemblies

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




CERTIFICATE OF COMPLIANCE

Certificate Number 20190509-R38702
Report Reference R38702-20190329
Issue Date 2019-MAY-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Kent Series AFC01/ASC01, Fire-Protective curtains, suffixed '455 Accordion', Fire-Protective Curtains, surface or between jamb mounted, rated up to and including 1 hr., for use in masonry or gypsum wall type constructions.

Kent Series AFC03/ASC03, Fire-Protective curtains, suffixed '690 Accordion', Fire-Protective Curtains, surface or between jamb mounted, rated up to and including 4 hr., for use in masonry wall type constructions and rated up to and including 3 hr., for use in gypsum wall type constructions.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

