## CERTIFICATE OF COMPLIANCE

Certificate Number Report Reference Issue Date 20190508-R38702 R38702-20161205 2019-MAY-08

Issued to:	Kent Smoke and Fire Curtains No 10, 7th street Al Qusais Industrial Area 2 Dubai UNITED ARAB EMIRATES
This certificate confirms that representative samples of	FIRE-PROTECTIVE CURTAINS See addendum page
	Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	ANSI/UL 10D, Standard for Fire Tests of Fire Protective Curtain Assemblies
Additional Information:	See the UL Online Certifications Directory at <u>https://iq.ulprospector.com</u> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Barnelly

Т

Bruce Mahrenholz, Director North American Certification Program



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <a href="http://ul.com/aboutul/locations/">http://ul.com/aboutul/locations/</a>

## CERTIFICATE OF COMPLIANCE

Certificate Number Report Reference Issue Date 20190508-R38702 R38702-20161205 2019-MAY-08

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Kent Series AFC01/ASC01, Fire-Protective Curtains, suffixed '455'or '455S', surface or between-jamb mounted, rated up to and including 1 hr., for use in gypsum or masonry wall type constructions.

Kent Series AFC03/ASC03, Fire-Protective Curtains, suffixed '690' or '690S', surface or between-jamb mounted, rated up to and including 3 hr., for use in gypsum or masonry wall type constructions.

Model(s) above may have suffix "E" for egress option.

Barnally

Bruce Mahrenholz, Director North American Certification Program



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <a href="http://ul.com/aboutul/locations/">http://ul.com/aboutul/locations/</a>