



warringtonfire

bre



certifire



CS/ KAFC-E/ R4 MAR 2021

**Kent**
Smoke and Fire Curtains

KENT AUTOMATIC FIRE CURTAIN - EGRESS

CUTSHEET



Kent Egress Curtain

DESCRIPTION

Kent Automatic Egress Curtains provide cross corridor fire separation without inhibiting the passage of occupants evacuating the building by utilizing an egress door that allows people to pass without retracting the curtain. It is used as a secondary means of escape.

Kent Egress curtains are used in elevator lobbies, cross corridors, staircase, and emergency exits. The curtain descends at a controlled speed upon receipt of a signal from a fire alarm using Kent's Guaranteed Gravity Fail-Safe System.

SYSTEM TESTED IN ACCORDANCE WITH


- Classified to UL 10D for a period of 180 minutes (690 Fabric)
- Classified to UL 10D for a period of 60 minutes (455 Fabric)
- UL 1784
- ASTM - E84 - VG 455 Fabric - Test Method for surface Burning characteristics of Building Material
- Fabric Impact Tested in accordance with BS 5234-2:1992
- BS 476 Pt 6 (fire propagation) & Pt 7 (surface spread of flame)
- Achieved class 0

COMPLIANCE

- NFPA 80 Compliance
- NFPA 101 Compliance
- NFPA 105 Compliance



Egress allows safe passage



Curtain stays closed after occupants pass through



warringtonfire

bre



certifire



CS/ KAFC-E/ R4 MAR 2021

KENT AUTOMATIC FIRE CURTAIN - EGRESS

CUTSHEET



Kent

Smoke and Fire Curtains

